

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Nilesh Kumar Jaiswal Microbiologist
(Name of Officers with designation) from Lab. UP: Jal Nigam Jaunpur PHED
inspected the M.S.D. Public School Asbaranpur, Jalalpur Jaunpur
(Name & Address of the school) on 28/07/2025 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. JNP/25/555 dated 30/07/2025
of District Lab. UP: Jal Nigam Jaunpur (PHED Lab) certified that
the M.S.D. Public School Asbaranpur, Jalalpur Jaunpur (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 28/07/2026

Signature with Seal: [Signature]
Name: अभिषेक मिश्रा
Designation: E. ग्रिड कार्यालय
Name & Address of the Office / Department: जल निगम, जापुर

To M.S.D. Public School Asbaranpur, UP: Jal Nigam, Jaunpur
Jalalpur, Jaunpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

67 | Page

S.K. Rly
PRINCIPAL
M.S.D. PUBLIC SCHOOL
Asbaranpur, Trilochan Mahadev, Jaunpur

मुन्शी गुला
MANAGER
M.S.D. PUBLIC SCHOOL
ASABARANPUR, TRILOCHAN MAHADEV, JAUNPUR



**District Level Water Analysis Laboratory,
Uttar Pradesh Jal Nigam,
(Rural), Kalichabad Sultanpur road District- Jaunpur -
222002**



Format No.-7.5 F- 01

TEST REPORT					
Report No.	JNP/25/555	Date -	30/07/2025	S. No -555	Page No. 1
Customer Details					
Office Name and Address	M.S.D Public School Asbaranpur Trilochan Mahadev Jalalpur Jaunpur				
Ref Letter No & Date	NA				
Basic Details of sample					
District	Jaunpur	Block	Jalalpur		
Gram Panchayat	Asbaranpur	Village	Asbaranpur		
Habitat	M.S.D Public School	Location	Asbaranpur		
Water Source	R O Water	Sample No.	JNP/25/555		
Quantity of Sample	1000 ml	Date of S.C.	26/07/2025		
Receiving Date	26/07/2025	S. Collector	Neeraj Dubey		
Sample Depositor	Neeraj Dubey	Sampling Method -	IS3025 (Part I)		
Analysis Start Date	29/07/2025	Analysis Complete Date	29/07/2025		
Environmental Condition					
Temperature	25 ± 3 °C		Relative Humidity	50±15%	
Technical Data of Analysis					
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
	2	3	4	5	6
1	pH @25°C	7.06	6.5	8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	0.95	1	5	IS 3025 (Part 10): 1984 : 2021 (Nephelometric method)
3	Total Dissolved Solids (mg/L)	95	500	2000	IS 3025 (Part 16): 1984 : 2023(Gravimetric method)
4	Chloride (mg/L)	30	250	1000	IS 3025 (Part 32): 1988: 2021(Argentometric method)
5	Total Alkalinity (mg/L)	100	200	600	IS 3025 (Part 23):1986 : 2021 (Potentiometric and indicator method)
6	Total Hardness (mg/L)	300	200	600	IS 3025 (Part 21): 2009: 2021(EDTA method)
7	Calcium (mg/L)	72.8	75	200	IS 3025 (Part 40):1991 :2019(EDTA Titrimetric method)
8	Magnesium (mg/L)	42	30	100	IS 3025 (Part 46): 1994: 2019 (Volumetric method)
9	Sulphate (as SO ₄)	36	200	400	APHA 24th Edition - 4500-SO ₄ Method E (Turbidimetric Method ,2023)
10	Nitrate(as NO ₃),mg/L	16	45	No relaxation	APHA 24th Edition - 4500-NO ₃ Method B (UV Screening Method ,2023)
11	Fluoride (as F)mg/L	0.234	1.0	1.5	APHA 24th Edition- 2023, 4500-F (C. Ion Selection Electrode Method)
12	Iron(as Fe)mg/L	BDL	1.0	No relaxation	APHA 24th Edition - 3500- Fe Method B (Phenanthroline ,2023)

- Note: -
1. This certificate refers only to the particular sample (S) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.
 5. This report valid for submitted sample only.

Report View by

Laboratory Contact details-Email- districtlabjaunpur@gmail.com

Mob- 8127284974

End of Test Report

S.K. Pali
PRINCIPAL
M.S.D. PUBLIC SCHOOL
Asbaranpur, Trilochan Mahadev, Jaunpur

मुन्नी गुला
MANAGER
M.S.D. PUBLIC SCHOOL
ASABARANPUR, TRILOCHAN MAHADEV, JAUNPUR

